

# **West Saline Water Users Association, Inc.**

P. O. Box 29  
6330 HWY 8  
New Edinburg, AR 71660-0029  
[wswu@pobox.com](mailto:wswu@pobox.com) or  
[www.westsalinewater.ruralwaterusa.com](http://www.westsalinewater.ruralwaterusa.com)  
Telephone 870 866-0534

The “Secondary Drinking Water Standards” of the Safe Drinking Water Act sets the Secondary Maximum Contaminant Level for **Sodium as 20 mg/L**. Our system customers and area care givers should make note of the following levels of **Sodium** to allow necessary adjustment for those **on a low sodium intake**. As a point of reference common soft drinks contain around 140 mg/L of **Sodium**.

**Sodium** levels for our water:

<b><u>Year</u></b>	<b><u>Result</u></b>
1991	93.0 mg/L
1994	91.0 mg/L
1999	85.4 mg/L
2001	88.7 mg/L
2004	75.7 mg/L
2007	74.0 mg/L
2008	82.6 mg/L
2010	79.4 mg/L
2013	76.3 mg/L
2016	86.1 mg/L
2019	75.7 mg/L